

Evidence of Performance

Airborne sound insulation of building elements

Test report 163 36489/Z1e

This is a translation of the test report 163 36489/Z1 of 22nd August 2008.




Client **Press Glas S.A.**
Nowa Wies
Kopalniana 9

42-262 Poczesna
Poland

Basis

EN ISO 140-1:1997+A1:2004
EN 20140-3 :1995+A1:2004
EN ISO 717-1 : 1996+A1:2006

Representation



Product	single pane glass
Designation	Float 12 mm
Size (w × h)	1230 mm × 1480 mm
Construction	12 mm Float
Area related weight	30 kg/m ²
Special items	-/-

Informations for use

This test report may be used to validate the sound reduction of a building element.

Validity for germany:

R_w corresponds to R_{w,P} for DIN 4109 Annex 1 table 40 a

Weighted sound reduction index R_w
Spectrum adaptation terms C and C_{tr}



$$R_w (C; C_{tr}) = 35 (-1; -3) \text{ dB}$$

Validity

The data and results given relate solely to the described, tested object.

Testing the acoustic properties does not allow any statement to be made on further characteristics of the present structure which could define performance and quality.

Notes on publication

The **ift** Guidance Sheet "Conditions and Guidance for the use of **ift** Test Documents" applies.

The cover sheet can be used as a summary.

Contents

This test report includes 6 pages

- 1 Test specimen
- 2 Test procedure
- 3 Test results
- 4 Instructions for use Data sheet (1 page)

ift Rosenheim
01. September 2008

J. Hessinger

Dr. Joachim Hessinger, Dipl.-Phys.
Head of test laboratory
ift centre for acoustic

Bernd Saß

Bernd Saß, Dipl.-Ing. (FH)
vice head of test laboratory
ift centre for acoustic

